



Weber Fire District

LP Gas Permit Application

2023 West 1300 North
 Farr West, Utah 84015
 Office: 801-782-3580

Submission Date: _____

INSTALLATION INFORMATION

PROJECT NAME		CONTACT:	
Physical Address:			
Mailing Address:			
Phone:		EMAIL:	
		<input type="checkbox"/> Tank <input type="checkbox"/> Cabinet – Size:	
Service Description:		Type of Vehicle Protection:	
<input type="checkbox"/> Above Ground		<input type="checkbox"/> Underground	
Foundation, Footing, or Backfill:			

LICENSED LP GAS INSTALLER INFORMATION

Company Name:	
Physical Address:	
Mailing Address:	
Phone:	
Contact:	EMAIL:

INFORMATION

Information shall include drawings and be submitted by a Utah-licensed LP Gas Installer to the Fire Marshal’s Office at: prevention@weberfiredistrict.gov
***Larger than 5000 Gal. must be sent to the State Fire Marshal’s Office for review and approval.**
 Insufficient information may cause a delay or rejection of plans. Plans and permits will not be released until all fees have been paid. Any questions, please reach out to 801.782.3580.

SAMPLE DRAWING

Installation must adhere to the Current **NFPA** standards and the current **International Fire Codes**.

The plan or sketch is to include:

- Size of tank(s) to be installed (water gallons)
- Distance from tank to property lines, existing buildings, streets, roads, and sidewalks. Overhead power lines and all sources of ignition in all directions.

IF NEEDED

- Type of approved vehicle protection to be used.
 - Guard posts or other approved means of protection for the tank and piping shall be provided.
 - ~ International Fire Code *current codes.
- Location of minimum 18 lb. B.C. fire extinguisher within 75 feet of dispenser.



LOCATION OF LP-GAS CONTAINERS

LP-GAS CONTAINER CAPACITY (water gallons)	MINIMUM SEPARATION BETWEEN LP-GAS CONTAINERS AND BUILDINGS, PUBLIC WAYS, OR LOT LINES OF ADJOINING PROPERTY THAT CAN BE BUILT ON.		MINIMUM SEPARATION BETWEEN LP-GAS CONTAINERS (feet)
	Mounded or underground LP-Gas containers (feet)	Above ground LP-Gas containers (feet)	
Less than 125	10	5	None
125 to 250	10	10	None
251 to 500	10	10	3
501 to 2,000	10	25	3
2,001 to 30,000	50	50	5
30,001 to 70,000	50	75	(0.25 of sum of the diameters of adjacent LP-Gas containers)
70,001 to 90,000	50	100	
90,001 to 120,000	50	125	

PLAN REVIEW DRAWING

Submit to the Fire Marshal's Office: prevention@weberfiredistrict.gov

